

EC Declaration of Conformity

INDEXA GmbH
Paul-Böhringer-Str. 3
74229 Oedheim
Deutschland

declares that the product

Type designation: 6000 S

Intended purpose: *Fire detection*

Frequency switching range: *1 RF channel 433,92 MHz*

RF power: *<10 mW ERP*

Channel separation: *> 25 kHz*

Duty cycle: *< 0,1 %*

Modulation: *pulse ASK/OOK*

Class of emission: *200KL1DAN*

Equipment class *I*

complies with the essential requirements of § 3 and the other relevant provisions of the FTEG (Article 3 of the R&TTE Directive) and CPD directive (1989/106/EC), when is used for its intended purpose.

Measures for the efficient use the radio frequency spectrum - Air interface of the radio systems pursuant to § 3(2) (Article 3(2))

Harmonised standards applied: *ETSI EN 300 220*

Protection requirements concerning electromagnetic compatibility § 3(1)(2), (Article 3(1)(b))

Harmonised standards applied: *EN 50130-4, EN 55022*

Health and safety requirements pursuant to § 3(1) 1. (Article 3(1) a))

Harmonised standards applied: *EN 60950-1*

Fire detection requirements pursuant to CPD directive (1989/106/EC)

Harmonised standards applied: *EN 14604, EN 54-5*



Bell, Tim

(Gesell. Geschaeftsfuehrer)

Oedheim

16.12.2008
